

CERTIFICATE

No:- 679 / उमोगशाला / 17 Dated:- 21-03-2025

It is certified that an inspection team headed by Sunil Kumar Junior Engineer UP Jal Nigam Rural (Kasganj/Etah) and with all team member inspected the Marehra Public School Marehra on 18.03.2025.

On the basis of on Water Test Report (Attached) report no. E97 dated 19.03.2025 of UPJN Rural Lab certified that the Marehra Public School Marehra has safe drinking water facilities for the students and members or staff of the institution.

Signature with Seal:-

Name :- Vishwajeet

Designation:- Executive Engineer

Name & Address of the Office / Department :-

Divisional Office of Executive Engineer UP Jal
Nigam Kasganj / Etah (Rural)


Principal
Marehra Public School
Affiliated to CBSE New Delhi
Aff. No. 2131124
Station Road, Marehra-Etah (U.P.)



कार्यालय अधिशासी अभियन्ता
खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), कासगंज।
कलैक्ट्रेट परिसर, सोरों रोड प्रहलादपुर, कासगंज, 207123

पत्रांक 679 / प्रयोगशाला / 17

दिनांक :- 21-03-2025

सेवा में,

सचिव/प्रबंधक,

Marehra Public School Marehra

District- Etah

विषय:- स्कूल के पंजीकरण हेतु जल नमूना जाँच रिपोर्ट के सम्बंध में।

उपरोक्त विषयक आप द्वारा लिखित पत्र दिनांक 07.03.2025 के कम में आपके द्वारा Marehra Public School Marehra District- Etah के पंजीकरण हेतु जनपदीय प्रयोगशाला एटा में जमा कराये जल नमूना की जाँच की गयी जो कि मानक के अनुरूप है।

अतः जल श्रोत स्कूल के प्रयोग हेतु उपयुक्त है।

संलग्नक उपरोक्तानुसार:- जल परीक्षण रिपोर्ट एवं प्रमाण पत्र

भवदीय


अधिशासी अभियन्ता



Principal
Marehra Public School
Affiliated to CBSE New Delhi
Aff. No. 2131124
Station Road, Marehra-Etah (U.P.)



Office of Executive Engineer, Jal Nigam
(Gramin) Etah U.P.
Water Analysis Report

Report No.E97

To,

Place/Source of Sampling- Marehra Public School Marehra
Village Name- Marehra Block- Marehra District- Etah
Name of Sample Collector- Haidar Date/Time- 18-03-2025 01:10 pm
Date of Analysis- 19-03-2025

S. No.	Parameter (Unit)	BIS Acceptable Limit	Unit Mg/l	BIS Permissible Limit in Absence of alternate source	Result	Remarks
1	Turbidity	1.0	NTU	5	2.48	
2	pH	6.5-8.5	-	No Relaxation	7.14	
3	Chloride	250	Mg/l	1000	88	
4	TDS	500	Mg/l	2000	480	
5	Alkalinity	200	Mg/l	600	68	
6	Fluoride	1	Mg/l	1.5	0.5	
7	Nitrate	45	Mg/l	No Relaxation	3.18	
8	Sulphate	200	Mg/l	400	48	
9	Total Hardness	200	Mg/l	600	9.6	
10	Iron	1	Mg/l	No Relaxation	0.01	
11	E-coliform	-	-	Shall not be Detectable in any 100ml Sample	0.0	
12	Calcium	75-200	Mg/l		58	
13	Magnesium	30-100	Mg/l		38	
14	Colour	5-15	Hazen Unit		5	
15	Odour	-	-		Agreeable	
16	Test	-	-		Agreeable	

Remark- The results reported above are as per the water sample supplied by client to the District Water Testing Laboratory, (Etah)U.P.


Principal
Marehra Public School
Affiliated to CBSE New Delhi
Aff. No. 2131124
Sector Road, Marehra-Etah (U.P.)


Authorised Signatory
U.P Jal Nigam (Village)